

10320S01 – Stove / Cooktop Exhaust Hoods

10320-All cooking stoves in non-sprinkled buildings, excluding one family residential units, shall be provided with an exhaust hood, a UL approved suppression system interconnected to the fire alarm system (if provided), and a fuel disconnect, unless an exception is granted in writing by the University Fire Marshal.

10321-All cooking stoves in sprinkled buildings, excluding one family residential units, shall be provided with an exhaust hood and a fuel disconnect, unless an exception is granted in writing by the University Fire Marshal.

10322-All cooking stoves in residential buildings (dormitories) shall be provided with an exhaust hood, a UL approved suppression system interconnected to the fire alarm system, and a fuel disconnect, unless an exception is granted in writing by the University Fire Marshal.