

10810S01- TOILET ACCESSORIES

Designers should specify toilet accessories that are "heavy-duty", durable, serviceable, and are manufactured by reputable companies. When possible, they should be recessed or otherwise "built-in" to the construction. Replacement parts should be easily obtained.

1. Toilet Partitions:

Provide_Marble, Stainless Steel, Painted Steel, or laminated plastic partitions.

Ceiling or wall-supported partitions shall be provided for easier floor maintenance. Partitions must be securely supported.

Hardware used should be heavy-duty and of the highest quality.

2. Double Robe Hook:

Each toilet stall shall have a heavy-duty satin-finished stainless steel double prong robe hook; rectangular wall bracket with back-plate for concealed mounting.

3. Towel Dispensers:

The designer should specify stainless steel combination towel dispenser and waste receptacle. Recessed or surface-mounted. Roll towels only! No fold towels!

4. Soap Dispensers:

Liquid Soap dispenser, Horizontal Tank Type: Fabricate for surface mounting, sized for 40 fl. oz. minimum capacity. Provide stainless steel piston, springs, and internal parts designed to dispense soap in measured quantity by pump action. Provide cover type 304 stainless steel, with unbreakable window-type refill indicator. Built-in, recessed, ceramic tile or Stainless Steel soap dishes should be furnished in each shower and tub.

5. Toilet Tissue Dispensers:

Dispensers for roll tissue should be clearly specified. Two dispensers should be placed at each water closet. Dispensers may be double-roll type or two single-roll type. Dispensers should be mounted in horizontal position. Dispensers should be of simple design but include a locking mechanism to prevent removal of roll until paper is used, no special key shall be required to remove roll. (small screw driver slot).

6. Sanitary Napkin Dispensers and Disposers:

Dispensers and disposers should be recessed stainless steel. One disposer should be located in each stall in every women's restroom and be installed at a convenient position. Disposers must not be installed behind water closets.

Napkin dispensers will not be required in every women's restroom. One or two dispensers per building, depending on size and type of occupancy, will usually be sufficient. Dispenser should be located in restroom which would receive the most use or be the most centrally located to female occupants. Assembly-type buildings, such as auditoriums, coliseums, and theaters, should have a dispenser in every women's restroom that is subject to use by the general public.