

# 15240S01- MECHANICAL SOUND, VIBRATION AND SEISMIC CONTROL

TYPE OF SPACE	MAXIMUM ACCEPTABLE NOISE CRITERIA (NC) CURVE
<b>GENERAL</b>	
CLASSROOMS/LIBRARIES	35
RESIDENCE-MULTIPLE OCCUPANT	35
BANQUET HALL/BALLROOMS	35
MUSEUM/DISPLAY AREA	35
LABORATORIES	40
RESTAURANT	40
RECREATION HALLS	40
LOBBIES/HALLS/CORRIDORS	40
CAFETERIA	45
RETAIL SPACE	45
KITCHEN/LAUNDRY/GARAGE	45
RESTROOMS/LOCKER ROOMS	45
<b>MEDICAL FACILITY</b>	
PATIENT ROOMS	25
OPERATING ROOMS/WARDS	35
WAITING ROOMS	40
<b>OFFICES</b>	
BOARD ROOMS	25
CONFERENCE ROOMS	30
PRIVATE OFFICE/RECEPTION ROOMS	35
OPEN OFFICE/STUDIO	40
TABULATION/COMPUTATION	45
<b>AUDITORIUMS</b>	
CONCERT HALLS/SOUND STUDIO	15
LEGITIMATE THEATER	25
MOVIE THEATER/LECTURE HALL	32
<b>SPORTS CENTER</b>	
COLISEUM	35
GYMNASIUM	40
SWIMMING POOL	50