



NOTE: COLLECTING LEG TO BE SAME DIAMETER AS STEAM MAIN  
 PROVIDE 1" DRAIN VALVE AT BOTTOM OF COLLECTING LEG  
 PROVIDE COLLECTING LEGS AT BUT NOT LIMITED TO:

- END OF MAINS
- AHEAD OF EXPANSION JOINTS
- AHEAD OF PRESSURE REDUCING VALVE
- AHEAD OF TEMPERATURE REGULATORS
- BOTTOM OF RISERS
- SEPERATORS
- AT 500 FT. INTERVALS ON LONG HORIZONTAL MAINS



UNIVERSITY OF KENTUCKY DESIGN & CONSTRUCTION STANDARDS

DRAWN BY <u>MA</u> APP. BY _____ DATE <u>4/11/90</u>	<table border="1"> <thead> <tr> <th>REVISION</th> <th>DATE</th> </tr> </thead> <tbody> <tr> <td>MJD</td> <td>12/3/92</td> </tr> <tr> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> </tr> </tbody> </table>	REVISION	DATE	MJD	12/3/92					TITLE : STEAM COLLECTION LEG	DRAWING NO.  <u>15520D03</u>
REVISION	DATE										
MJD	12/3/92										