

# 15840S01 - Air Terminal Units

## I VAV Boxes:

All VAV boxes and control valves must have, at minimum, a 24" x 24" access space for maintenance, including removal of coils, damper arms, reheat valves, etc. Space must be maintained to top of acoustical ceiling grid.