

15880 Air Diffusers

1.0: Air diffusers installed in Medical Center buildings should meet the following requirements:

- a. Diffusers and return/exhaust grilles in drop ceilings shall be 24" x 24" drop-in type diffusers. Diffusers built into light fixtures are not allowed.
- b. Diffusers and return/exhaust grilles shall have pin perforated faces when the entire room or area is replaced or in new buildings/construction. If diffusers or grilles are installed in an area with existing diffusers of other face types, then the new diffusers shall match the existing unless the project replaces the entire room or area.