



TYPICAL COMMUNICATION BANK

Notes:

1. Top of concrete encasement shall be installed a minimum of 24" below finished grade
2. Provide protective fence if trench is outside of construction area.



UNIVERSITY OF KENTUCKY DESIGN & CONSTRUCTION STANDARDS

DRAWN BY JRZ APP. BY DJG DATE 2-87	REVISION DATE 1/11/91	TITLE : CONSTRUCTION DETAILS COMMUNICATION DUCT BANK	DRAWING NO. 16110D02
--	--------------------------	---	-------------------------