

16480S01 - MOTOR CONTROL

ELECTRICAL STARTERS AND INTERLOCKS

Electrical contactors and motor starters shall be heavy duty.

NEMA Size I through Size 5 starters shall be suitable for the addition of at least four (4) external electrical interlocks of any arrangement, normally open or normally closed.

All starters shall be supplied with a minimum of two (2) interlock contacts.

All magnetic starters shall be equal to Square D Co., Class 8536.

All combination starters shall be equal to Square D Co., Class 8538 or 8539.

An overload element identification list showing type and size installed in each starter shall be provided in the Operation and Maintenance Manuals and this information must be marked on the starter.