



SECTION AA

LIGHT BROOM FINISH

NOTE: PINS (DOWELS) AND PVC TUBING ARE SHOWN ENLARGED FOR CLARITY.

1/2" EXPANSION JOINT CANE FIBER WITH ZIP STRIP CAP

6" x 6" #10 W.W.F. PULLED TO MIDPOINT OF SLAB

DENSE GRADE OR STONE AS REQUIRED OR SPECIFIED

1 1/2" TOOLED JOINT PLUS 1/4" SAW CUT WITH OWNER APPROVAL JOINT MAY BE SAWN

BRASS PINS - MIN. 1" DIA. FOR LOCATING CONDUIT

NEW CONCRETE WALKWAY 4,000 PSI

DEPTH OF SLAB TO BE SPECIFIED FOR EACH JOINT OR AREA - MINIMUM DEPTH 4" FOR ANY APPLICATION

WIDTH OF SIDEWALK

NUMBER OF PINS

2'-0" TO 4'-0"
4'-1" TO 6'-0"
GREATER THAN 6'-0"

2
3
1 PIN EVERY 2 FEET

CRACK CONTROL JOINT NOTE: IN CASES OF MONOLITHIC CURB, EXTEND CONTROL JOINT THROUGH CURB

SLIP TUBE ON DOWELS 3/4" DIA. PVC TUBE, CAULK ENDS

SHEET PLASTIC (ABOVE 90° F)

1/3" SAW CUT OF SLAB

2" PVC PIPE LOOSELY CAPPED AT SPECIFIED LOCATIONS

N:\COLLINS\CONCRETE_CONTRACT_DWGS\SIDEWALK.DWG



CONCRETE SPECS
CONCRETE SIDEWALK- UK STANDARD

BLDG #
0000

DATE: 11/16/98
DWN BY: SOT
REV. DATE: 6/7/01
REV. BY: CMB