

07210S01- Building Insulation

- 1.0 Provide insulating materials that comply with requirements and with referenced standards and for preformed units, in sizes to fit applications indicated, selected from manufacturer's standard thicknesses, widths and lengths.
- 2.0 Batt insulation shall not be exposed in any area of the building. It must be encapsulated ie: as installed between drywall. This shall include insulated walls that extend above the ceiling.
- 3.0 Batt insulation shall not be installed on ceilings of any type.
- 4.0 Batt insulation shall not be allowed to come in contact with any moisture. Contaminated material shall be removed and replaced with new material.