

UNIVERSITY FIRE RATINGS

In University buildings protected throughout by an approved, supervised automatic sprinkler system, and installed to the requirements of NFPA 13:

Newly introduced contents, furnishing, and mattresses shall meet the applicable requirements of the most recently adopted edition of NFPA 101 for healthcare occupancies and NFPA 1 for all other occupancies.

Additionally, all mattresses shall be tested and approved in accordance with 16 CFR 1632, "Standard for the Flammability of Mattresses and Mattress Pads".

In University buildings not protected throughout by an approved, supervised automatic sprinkler system:

Newly introduced contents, furnishing, and mattresses shall meet the requirements set forth for each type of furnishing.

Upholstered Furniture shall meet one of the following requirements:

- 1) Components meet the requirements for Class I when tested to NFPA 260 standards *or* ASTM E 1353.
- 2) Components meet the requirements of California Technical Bulletin 117-2013.
- 3) Mocked up composites meet the requirements of NFPA 261 *or* ASTM E 1352.
- 4) Mocked up composites meet the requirements of California Technical Bulletin 133-

2013.

Mattresses:

- 1) Shall be tested and approved in accordance with 16 CFR 1632, "Standard for the Flammability of Mattresses and Mattress Pads".
- 2) Shall have limited rates of heat release when tested in accordance with ASTM E 1590.