

## 072100S01- THERMAL INSULATION

Provide insulating materials that comply with requirements and with referenced standards and for preformed units, in sizes to fit applications indicated, selected from manufacturer's standard thicknesses, widths and lengths.

- 1.0 Batt insulation shall not be exposed in any area of the building. It must be encapsulated ie: as installed between drywall. This shall include insulated walls that extend above the ceiling.
- 2.0 Batt insulation shall not be installed on ceilings of any type.
- 3.0 Batt insulation shall not be allowed to come in contact with any moisture. Contaminated material shall be removed and replaced with new material.