

FCR 11

Office of the President
December 11, 2012

Members, Board of Trustees:

REPAIR/UPGRADE/EXPAND CENTRAL PLANTS
(REPLACE COOLING TOWER AT MEDICAL CENTER COOLING PLANT)

Recommendation: that the Board of Trustees approve the initiation of the Repair/ Upgrade/ Expand Central Plants (Replace Cooling Tower at Medical Center Cooling Plant) capital project.

Background: The Medical Center Cooling Plant provides chilled water to the campus loop as well as the Medical Center. The cooling tower is in excess of 10 years old. This tower does not meet today's cooling capacity requirements due to increased loads and other inefficiencies.

The project has an estimated scope of \$870,000, and will be funded with General Funds.

Action taken: Approved Disapproved Other _____