## **FCR 12**

Office of the President December 11, 2012

Members, Board of Trustees:

## REPAIR/UPGRADE/IMPROVE MECHANICAL INFRASTRUCTURE (STEAM LINE-FARM ROAD)

<u>Recommendation</u>: that the Board of Trustees approve the initiation of the Repair/ Upgrade/ Improve Mechanical Infrastructure (Steam Line-Farm Road) capital project.

<u>Background</u>: The Farm Road steam line delivers steam from the campus steam plants to the following buildings: Gluck Equine, Plant Science, ES Good Barn, KY Tobacco Center, and BCTCS. The steam is used for building heat, steam humidification, cleaning, and sterilizers. This project replaces the steam and condensate piping from the ES Good Barn to the Gluck Building. The 25 year old piping has deteriorated beyond repair. The upstream and downstream sections have been recently replaced.

The scope of the legislative authorized project is \$835,000, and will be funded with General Funds.

Action taken:	☑ Approved	☐ Disapproved	☐ Other —	