

FCR 6

Office of the President
June 11, 2013

Members, Board of Trustees:

REPAIR/UPGRADE/IMPROVE BUILDING SYSTEMS
UNIVERSITY OF KENTUCKY HEALTHCARE
(GOOD SAMARITAN HOSPITAL AIR HANDLING UNITS)

Recommendation: that the Board of Trustees approve the initiation of the Repair/Upgrade/Improve Building Systems – University of Kentucky HealthCare (Good Samaritan Hospital Air Handling Units) capital project.

Background: This project will replace air handling units (AHU) 19 and 21 in Good Samaritan Hospital. AHU 19 heats and cools patient areas on floors four through seven. AHU 21 serves the second floor operating rooms and the pre-operative and post-operative acute care unit areas. These AHUs are 42 years old, in poor mechanical condition and do not provide sufficient airflow to meet current code requirements. Replacement of these AHUs is needed to insure patient and staff comfort and air quality and to meet regulatory requirements.

The scope of this project is \$2.8 million, well within the \$10 million legislative authorization and will be funded with clinical revenues.

Action taken: Approved Disapproved Other _____