

088100S01 GLASS GLAZING Safety Glazing Identification

1.0. Labeling Requirements

Each light of Safety Glazing material manufactured, distributed, imported or sold for use in hazardous locations and installed in a location within the University of Kentucky Medical Center shall be permanently labeled by etching, sandblasting or firing ceramic material on the safety glazing material. The label shall be legible and visible after installation. Safety glazing labeling shall not be used on materials other than Safety Glazing materials.

1.1. Marking

Each light of Safety Glazing material installed in hazardous locations within the University of Kentucky Medical Center shall bear a permanent identifying mark issued by an approved agency which specifies the marking agency, whether manufacturer or installer, and the test standard.

2.0 Specific Hazardous Locations

The following shall be hazardous locations for the purpose of glazing:

- A. Glazing in ingress and means of egress doors.
- B. Glazing in fixed and sliding panels (pass thru windows), and panels in swinging doors.
- C. Glazing in all unframed swinging doors.
- D. Glazing on doors and enclosures for medical use of hot tubs, whirlpools, saunas, steam rooms, bathtubs and showers. In any portion of a building wall enclosing these compartments where the bottom exposed edge of the glazing is less than 60 inches above a standing surface.
- E. Glazing on individual fixed or operable panels adjacent to a door where the nearest exposed edge of the glazing is within a 24 inch arc of either vertical edge of the door in a closed position and where the bottom exposed edge of the glazing is less than 60 inches above the walking surface.
- F. Exposed area of an individual pane greater than 9 square feet.
- G. Exposed bottom edge less than 18 inches above the floor.
- H. Exposed top edge greater than 36 inches above the floor.
- I. The finished floor or walking surface within 36 inches on both sides of the glazing.
- J. All glazing in guards and railings regardless of area or height above a walking surface.