

## **103500S01 Stove / Cooktop Exhaust Hoods**

1.0. All cooking stoves in non-sprinkled buildings, excluding one family residential units, shall be provided with an exhaust hood, a UL approved suppression system interconnected to the fire alarm system (if provided), and a fuel disconnect, unless an exception is granted in writing by the University Fire Marshal.

2.0. All cooking stoves in sprinkled buildings, excluding one family residential units, shall be provided with an exhaust hood and a fuel disconnect, unless an exception is granted in writing by the University Fire Marshal.

3.0. All cooking stoves in residential buildings (dormitories) shall be provided with an exhaust hood, a UL approved suppression system interconnected to the fire alarm system, and a fuel disconnect, unless an exception is granted in writing by the University Fire Marshal.