

## 223000S00- PLUMBING (Ameresco)

See [006290S01 to 006290S04](#) for ESCO Buildings List / Compliance Requirements.

Commercial (public use) installations - A water closet for public use, including a commercial building, shall not exceed 1.6 gallons per flush.

Urinals - A urinal shall not exceed 1/8 gallon per flush (pint urinal).

Lavatories - Lavatories in restrooms of public facilities shall be equipped with a tamper proof aerator which shall limit the flow of water to a maximum of 0.50 gallons per minute. A locking key shall be used to remove the aerator.

Lavatory faucets (other than those in restrooms of public facilities) - be equipped with a flow control device which shall limit the flow of domestic to a maximum of 1.5 gallons per minute.

Sink faucets - be equipped with a flow control device which shall limit the flow of domestic hot water to a maximum of 1.5 gallons per minute.

Showers - A shower used for other than safety reasons shall be equipped with an approved flow control device which shall limit the total flow to a maximum of 1.5 gallons per minute per shower head.