

087100S04 DOOR HARDWARE Door Hinges

- 1.0 All hinges shall be five knuckle with ball bearings. All hinges shall have fully concealed bearing and self-lubricating sleeves.
- 2.0 Door up to 42 inches in width shall use three 4 1/2 inch hinges. Doors over 42 inches in width shall have three 5 inch hinges. Doors 90 inches and taller shall use a minimum of 4 hinges.
- 3.0 All Exterior doors that swing out shall have non-removable pins.
- 4.0 All hinges on exterior door shall have hinges constructed of solid bronze with the specified plated finish. All interior door hinges shall be steel with the specified plated finish.
- 5.0 Suggested manufacturers, but not limited to:
 - Hager Companies
 - McKinney Products Company
 - Mont-Hard Corporation
 - Sargent Manufacturing
 - Stanley