087100S08 DOOR HARDWARE Thresholds

Floor heights shall remain level at all thresholds and/or transitions between flooring material. Contractor shall remove subfloor material and/or provide trowelable underlayment as required to allow for flush and level transitions between surfaces.

087100S08 DOOR HARDWARE Thresholds

Dated: 12/2015

Applies to: Med Center / Hospital Only

University of Kentucky