
261300D01 MEDIUM VOLTAGE SWITCHGEAR Construction Details - Typical Underground Switch Vault





TYPICAL UNDERGROUND SWITCH VAULT

NO SCALE


GENERAL NOTES:

- 1. SWITCH VAULT MAY BE PRE-CAST OR CAST IN PLACE CONCRETE, WALLS AND FLOOR ONLY.
- SWITCH VAULT COVER AND TOP ASSEMBLY SHALL COMPLY WITH ASTM C857 A-16 LOAD DESIGNATION AND CONSIST OF TWO LIFT OUT CONCRETE LIDS. EACH LID SHALL HAVE A ACCESS HATCH CONSISTING OF TWO HINGED DOORS - HALLIDAY ALUMINUM HATCH H2R SERIES WITH THE PADLOCK OPTION. THE DOORS SHALL OPEN IN THE SAME DIRECTION AND ADJOIN ON THE SHORT SIDES.
- 3. COVERS AND TOP ASSEMBLY SHALL BE CONCRETE GRAY IN COLOR, WHEN INSTALLED IN STREETS, WALKS OR PAVED AREAS AND GREEN IN COLOR WHEN INSTALLED IN GRASS AREAS.
- 4. OPERATING SECTION SHALL HAVE HINGED COVER WITH TWO DROP-IN STYLE HANDLES.

261300D01 Medium Voltage Switchgear Dated: 8/2018 Applies to: All Projects University of Kentucky

261300D02 MEDIUM VOLTAGE SWITCHGEAR Construction Details - Typical Underground Switch Vault






SECTION A-A

TYPICAL UNDERGROUND SWITCH VAULT

NO SCALE


FOR 4 WAY, 5 WAY AND 6 WAY

261300D02 Medium Voltage Switchgear Dated: 8/2018 Applies to: All Projects University of Kentucky Page 2 of 6




NO SCALE

261300D03 Medium Voltage Switchgear Dated: 8/2018 Applies to: All Projects University of Kentucky



NO SCALE

261300D04 Medium Voltage Switchgear Dated: 8/2018 Applies to: All Projects University of Kentucky




6 WAY UNDERGROUND SWITCH VAULT

NO SCALE

261300D05 Medium Voltage Switchgear Dated: 8/2018 Applies to: All Projects University of Kentucky 261300D06 MEDIUM VOLTAGE SWITCHGEAR Construction Details - COVER BOLT DOWN DETAIL





COVER BOLT DOWN DETAIL

NO SCALE

261300D06 Medium Voltage Switchgear Dated: 8/2018 Applies to: All Projects University of Kentucky