

265300S01 Exit Signs

- 1.0 All exit signs shall be Lithonia Signature Series with LED (light emitting diodes) or equal. The fixture shall have 3/4 inch letter stroke and have a green lens for the panel insert. Red may be used on renovations to match existing exit signs. The housing color shall be white.
- 2.0 Maximum power consumption shall be 2.5 watts per hour.
- 3.0 All exit signs shall be illuminated at all times, and be connected to the emergency power system. Battery back-up units are permitted if an emergency power system is not available in the building.
- 4.0 The back-up battery shall be sealed, maintenance-free, nickel-cadmium type with a minimum 10 year nominal life.
- 5.0 The battery charger system shall be fully automatic, solid state, with constant current.