

FCR 10

Office of the President
September 9, 2016

Members, Board of Trustees:

RENOVATE/IMPROVE UK GOOD SAMARITAN HOSPITAL
FACILITIES CAPITAL PROJECT
(REPLACE AIR HANDLING UNITS)

Recommendation: that the Board of Trustees approve the initiation of the Renovate/Improve UK Good Samaritan Hospital Facilities Capital Project (Replace Air Handling Units).

Background: Pursuant to Administrative Regulation 8:2, any capital project with an estimated cost of \$600,000 or more must be approved by the Board prior to initiation. This Project will replace two air handling units (#24 air handling unit and the roof top #54 air handling unit) at UK Good Samaritan Hospital.

Patient areas on the first, third, and fifth floors are heated and cooled by the #24 air handling unit while the operating rooms on the fifth floor are serviced by the #54 roof top air handling unit. The replacement of the 33-year-old units will ensure patient safety and comfort, air quality, and compliance with regulatory requirements.

This \$1,500,000 project will be funded with agency funds and is well within the \$25,000,000 authorized by the 2016 Session of the Kentucky General Assembly.

Action taken: Approved Disapproved Other_____



New Student Center (Under Construction)

UNIVERSITY OF KENTUCKY®

FCR 10 - RENOVATE/IMPROVE UK GOOD SAMARITAN HOSPITAL FACILITIES CAPITAL PROJECT (REPLACE AIR HANDLING UNITS)



Imagery: Pictometry (Spring 2016)
Created by UK Facilities Information Services
GeospatialRequests@uky.edu
REV: 20160331